



NOTES:

1. LONG WATER SERVICE CROSSINGS SHALL RUN FROM THE SIDE LOT LINE ON ONE SIDE OF THE STREET TO A SIDE LOT LINE ON THE OTHER SIDE OF THE STREET.
2. 4" SCH 40 PVC CONDUIT SHALL EXTEND 2' MINIMUM BEHIND FACE OF CURB.
3. BACKFILL TRENCH, FROM TOP OF CONDUIT TO STREET SUBGRADE, WITH CEMENTUOUS FLOWABLE FILL.
4. SERVICE LINE SHALL BE BORED IF PVMT. EXISTS.

REVISION	BY	DATE	LONG WATER SERVICE (SINGLE)	
			STANDARD DETAILS	
			CITY OF JENKS, OKLAHOMA	
			ENGINEERING DEPARTMENT	
			DATE: 4-11-22	STANDARD NO. WAT-11