



3/4" & 1" TAP MATERIALS LIST

1. TAPPING SADDLE: 3/4" OR 1" - FORD OR SMITH-BLAIR, MODEL 315, SINGLE BAND, IP THREAD, OR MUELLER DR1S MODEL, SS SINGLE BAND IP THREAD.*
2. CORPORATION STOP:
3/4" - FORD, MODEL #F1100-3-NL, IP THREAD x CTS COMPRESSION FITTING, OR MUELLER 3/4" P15028N.**
1" - FORD, MODEL #F1100-4-NL, IP THREAD x CTS COMPRESSION FITTING, OR MUELLER 1" P15028N.**
3. SERVICE LINE: 3/4" OR 1" - TUFF-TUBE, BLUE.
4. COMPRESSION FITTING: 3/4" OR 1" - CTS WITH STIFFENER INSERTS.
5. METER SETTER: 3/4" OR 1" - FORD OR MUELLER BRASS/COPPER, CTS x FEMALE IP OR CTS x CTS.
6. METER: 3/4" OR 1" - PROVIDED BY THE CITY OF JENKS.
7. METER CAN:
3/4" - BROOKS, B2200.
1" - BROOKS, 1220-12.
8. METER CAN LID:
3/4" - BROOKS, CAST IRON LID W/SITE HOLE TOUCH READ.
1" - BROOKS, 1220-CT LID.
9. FITTING: 3/4" OR 1" - CTS x CTS
10. 3/4" OR 1" - METER SHUT OFF VALVE.
11. 3/4" OR 1" - METER FREEZE PLATE.
12. 3/4" OR 1" - CLEAN RIVER/FILL SAND.
13. 3/4" OR 1" - METER SETTER SHALL BE 9" BELOW LID (FINAL GRADE).
14. STABILIZATION BAR.
15. CUSTOMER SERVICE LINE.

* RANGE SHALL BE FOR C900 OR DR21 PVC PIPE.

** INSTALL CORPORATION STOP SO OPERATING LEVER IS OVER CENTERLINE OF MAIN.

REVISION	BY	DATE	3/4" & 1" METER SETTING STANDARD DETAILS	
			DATE: 4-11-22	STANDARD NO. WAT-08