


**96' DIAMETER  
CUL-DE-SAC**



**120' HAMMERHEAD**

DEAD END LENGTH (FEET)	STREET WIDTH (FEET)	TURN-A-ROUNDS REQUIRED
0-150	20	NONE REQUIRED
151-500	20	120' HAMMERHEAD OR 96' DIAMETER CUL-DE-SAC IN ACCORDANCE WITH DETAILS ABOVE
501-750	26	120' HAMMERHEAD OR 96' DIAMETER CUL-DE-SAC IN ACCORDANCE WITH DETAILS ABOVE
OVER 750		SPECIAL APPROVAL REQUIRED

NOTE:  
REFER TO CURRENT VERSION OF INTERNATIONAL FIRE CODE.

**DEAD END STREET FOR  
FIRE PROTECTION ACCESS  
STANDARD DETAILS**

CITY OF JENKS, OKLAHOMA

ENGINEERING DEPARTMENT

DATE: 4-11-22

STANDARD NO. MISC-02