



NOTES:

1. SLIDING TRENCH SUPPORTS SHALL NOT BE PLACED BELOW THE TOP OF PIPE.
2. WATER TABLE CRADLE SHALL BE INSTALLED FOR THE FULL WIDTH OF THE TRENCH EXCAVATION.
3. FOR RIGID PIPES USE THE STANDARD TRENCH WIDTH. SEE TABLE FOR FLEXIBLE PIPES.

| MINIMUM TRENCH WIDTH FOR FLEXIBLE PIPES | |
|---|-------------------|
| PIPE I.D. | MIN. TRENCH WIDTH |
| 8" - 12" | 3' - 0" |
| 14" - 18" | 4' - 6" |
| 20" - 24" | 6' - 0" |
| 26" - 30" | 7' - 6" |
| 32" - 36" | 9' - 0" |

NOTE:
FLEXIBLE PIPES ARE HP-STORM AND PVC.
FOR ALL OTHER PIPES USE THE
STANDARD TRENCH WIDTH.

| REVISION | BY | DATE | WATER TABLE CRADLE FOR FLEXIBLE PIPE | |
|----------|----|------|---|----------------------|
| | | | STANDARD DETAILS | |
| | | | CITY OF JENKS, OKLAHOMA | |
| | | | ENGINEERING DEPARTMENT | |
| | | | DATE: 4-11-22 | STANDARD NO. MISC-05 |